

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2253 / जल परीक्षण / 73

Dated: 21.06.2025

It is certified that an inspection team headed by Neeraj Kumar (Lab Attendent)

(Name of Officers with designation) from U.P. Jal Nigam (Gramin) PHED

inspected the Green Light Sr. Sec. Public School Abhipura Bijnoy

(Name & Address of the school) on 19.06.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. BJ/1120 dated 20.06.2025

of District Level Water Analysis (PHED Lab) certified that the

Laboratory U.P. Jal Nigam (Gramin) BIJNOY

Green Light Sr. Sec. Public School Abhipura Bijnoy (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till N.A.



Signature with Seal: 
Name : AKSHAY KUMAR
Designation : A.E.
Name & Address of the Office / Department : U.P. Jal Nigam (Gramin) Bijnoy

To Green Light Sr. Sec. Public School Abhipura Bijnoy (U.P.)
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Analysis Report

District Level Water Analysis Laboratory U.P, Jal Nigam Bijnor

Report No. 1128 *2253/0124/2025* Date *21.06.2025* Page No. *73*

Customer Details

Office Name and Address: Green Light Sr.Sec. Public School Abhipura Bijnor
Ref Letter No & date: Date: 19-06-2025

Basic details of sample

District	Bijnor	Block	-----
Gram Panchayat	-----	Village	-----
Habitation	-----	Location	Green Light Sr.Sec. Public School
Water Source	Submersible	Sample No.	BJ/1128
Quantity of Sample	1 Lt	Date of S.C	20-06-2025
Receiving Date	20-06-2025	Sample Collector	Neeraj Kumar
Sample Depositor	Neeraj Kumar	Sampling Method Used	IS 17614 (Part 1):2021
Analysis Start Date	20-06-2025	Analysis Completion date-	21-06-2025

Environmental Condition

Temperature	23.2°C	Relative Humidity	Upto 55.6%
-------------	--------	-------------------	------------

S.R	Analyzed Parameters (Unit of Measurement)	Observed Value	Specified Values as per IS 10500:2012		Ref Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
2	pH	7.712	6.5-8.5	6.5-8.5	IS 3025 P-11:2022
3	Turbidity (NTU)	0.98	1.0	5.0	IS 3025 P-10:2023
4	TDS(mg/l)	229.0	500	2000	IS 3025 P-16:2023
5	Chloride(mg/l)	13.0	250	1000	IS 3025 P-32:2019
6	Total Alkalinity(mg/l)	185.0	200	600	IS 3025 P-23:2023
7	Total Hardness(mg/l)	208.0	200	600	IS 3025 P-21:2019
8	Calcium(mg/l)	35.81	75	200	IS 3025 P-40:2024
9	Magnesium (mg/l)	29.16	30	100	IS 3025 P-46:2023
10	Nitrate (mg/l)	0.93	45	45	Apha24 th edition -4500 NO ₃ ⁻ Method B (UV Screening Method):2023
11	Sulphate (mg/l)	8.87	200	400	Apha24 th edition-4500 SO ₄ ⁻ Method E (Turbidimetric Method):2023
12	Iron (mg/l)	0.09	1.0	1.0	Apha 24 th edition -3500 Fe method B (Phenanthroline Method):2023
13	Fluoride(mg/l)	0.202	1.0	1.5	Apha24th edition-4500 F ⁻ Method C (Electrode method):2023
14	E.coli	0	Shall not be detectable in 100 ml sample		IS 15185:2016
15	Total Coliform	0	Shall not be detectable in 100 ml sample		IS 15185:2016

Note -

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.

prepared By: *Amrit*
Lab Technician

Amrit
Authorized Signatory
Technical Manager
(Microbiological)

Amrit
Authorized Signatory
Technical Manager
(Chemical)